

IEC 62716:2013 Photovoltaic (PV) modules

- Ammonia corrosion testing -Confirmation of test results

VDE Renewables File Ref.: ET-20220518-088

Applicant: Jiangsu Runergy New Energy Technology Co., Ltd. Unit 101, Building 1, 58 Xiangjiang Road, Yancheng Economic and Technological Development Zones, Yancheng, Jiangsu, China.

Product: Crystalline silicon Photovoltaic (PV)-Modules

Type:

A) HY-DH144P8-XXX	A) HY-DH144P8-XXXb/B/T
B) HY-DH132P8-XXX	B) HY-DH132P8-XXXb/B/T
C) HY-DH120P8-XXX	C) HY-DH120P8-XXXb/B/T
D) HY-DH108P8-XXX	D) HY-DH108P8-XXXb/B/T
E) HY-DH144N8-XXX	E) HY-DH144N8-XXXb/B/T
F) HY-DH132N8-XXX	F) HY-DH132N8-XXXb/B/T
G) HY-DH120N8-XXX	G) HY-DH120N8-XXXb/B/T
H) HY-DH108N8-XXX	H) HY-DH108N8-XXXb/B/T
-	-

XXX in the type replace the power in Watt and can be any number between:

520 – 550 for A)	470 – 505 for B)	430 – 465 for C)
390 – 420 for D)	540 – 585 for E)	490 – 545 for F)
450 – 495 for G)	405 – 445 for F)	

Manufacturer:	Runergy PV	Technology	(Thailand)	Co., Ltd.
---------------	------------	------------	------------	-----------

Standard: IEC 62716:2013, Ammonia corrosion testing

Test conditions

Hours including heating up:	8 h
NH3 -concentration (ppm):	6667
Chamber temperature:	60°C
Relative Humidity:	100 %
Hours including cooling:	16 h
NH3 -concentration (ppm):	0
Chamber temperature:	23°C
Relative Humidity:	75 %

VDE RENEWABLES GMBH Siemensstraße 30 63755 Alzenau, Germany Managing Director: Burkhard Holder
 Tel:
 +49 69 6308 5300

 Fax:
 +49 69 6308 5320

 Email:
 renewables@vde.com

 www.vde.com/renewables

Location: Alzenau District Court: Aschaffenburg Registration No: HRB 13820 Tax Number: 204/141/20793 Bank Information: Deutsche Bank AG IBAN: DE14 5007 0010 0235 5006 01 BIC: DEUTDEFFXXX



Pass criteria

Power degradation:	< 5%
Dry Insulation:	> 40 MΩm²
Wet insulation:	> 40 MΩm²
Ground continuity:	< 0.1Ω

Bypass diode functionality: Shall be functional after test

Summary of test results:

Maximum power degradation:	allowed	max. 5 %
	measured	max. 0.41 %

The measured degradation is below the allowed degradation.

Dry insulation resistance:	required	min. 15.5 MΩ
	measured	>1000 MΩ

The measured dry insulation resistance is above the limit.

Wet insulation resistance:	required	min. 15.5 MΩ
	measured	>1000 MΩ

The measured wet insulation resistance is above the limit.

Ground continuity test:	required	max. 0.1Ω
	measured	max. 0.0153Ω

The measured ground continuity test is below the limit.

Visual inspection: No findings

Bypass diode functionality test: Still functional after test

The complete test results and the relevant bill of materials are given in Test Report No.: TRPVM- ET-20220518-088-1.

VDE Renewables GmbH

Zhiyao Wang

Zhiyao Wang Shanghai, 2022-10-24

Deantien

Dean Wen